

XLP/PVC TRAY CABLE - #14AWG TYPE TC-ER SUNLIGHT RESISTANT, DIRECT BURIAL XHHW-2 CONDUCTORS, PVC JACKET, 600VOLTS

CONSTRUCTION:

CONDUCTOR CLASS B STRANDED BARE COPPER PER ASTM B-3.

INSULATION FLAME-RETARDANT CROSSLINKED POLYETHYLENE (XLP) TYPE XHHW-2 PER UL 44. INSULATED CONDUCTORS RATED 90DEG C WET OR DRY.

CONDUCTOR IDENTIFICATION INSULATED CONDUCTORS COLOR CODED PER ICEA METHOD 1 TABLE E-2.

ASSEMBLY CONDUCTORS ARE CABLED TOGETHER WITH A SUITABLE TAPE SEPARATOR AS NEEDED.

OVERALL JACKET SUNLIGHT RESISTANT, FLAME RETARDANT, BLACK PVC PER UL 1277, WHICH PROTECTS AGAINST HEAT, FLAME, CHEMICALS, MOISTURE, AND MECHANICAL DAMAGE.

Charlotte Wire Part#	Size AWG	Number of Conductors	Insulation Thickness (in.)	Jacket Thickness (in.)	Overall Diameter (in.)	Approx. Net Wt. (Lbs/Mft.)
CW02471*	14	2	.030"	.045"	*.24"x.38"	72
CW02472	14	3	.030"	.045"	.40"	93
CW02473	14	4	.030"	.045"	.44"	118
CW02474	14	5	.030"	.045"	.48"	142
CW02475	14	7	.030"	.045"	.52"	181
CW02476	14	9	.030"	.060"	.64"	240
CW02477	14	10	.030"	.060"	.69"	268
CW02478	14	12	.030"	.060"	.72"	305
CW02479	14	15	.030"	.060"	.77"	366
CW02480	14	19	.030"	.060"	.82"	458
CW02481	14	20	.030"	.060"	.90"	505
CW02482	14	25	.030"	.080"	1.00"	635
CW02483	14	30	.030"	.080"	1.08"	740
CW02484	14	37	.030"	.080"	1.14"	890

*2/c is flat construction and TC only. TC-ER rating applies to 3 conductors or more.

APPLICATION:

Control, signal, or lighting circuits rated 600Volts where a high temperature, low dielectric loss insulation is needed. May be used as sunlight resistant, directly buried, and wet or dry locations. Per NEC Articles 336 and 392, approved for installation in

- 1) raceways and cable tray systems including ladders, troughs, channels, solid bottom trays, and other similar structures,
- 2) lighting, control, and signal circuits,
- 3) aerial locations where supported by a messenger wire,
- 4) hazardous locations per NEC Article 501 Class 1 Division 2, and
- 5) Class 1 circuits as permitted in NEC Article 725.

STANDARDS:

UL Standard 1277 for Type TC Cables.

Passes UL and IEEE383 70,000BTU Flame Test.

UL Standard 44 for XHHW-2 Conductors.

ICEA S-95-658/NEMA WC70 for Nonshielded 0-2kv Cables.

NEC Articles 336 & 392 for Tray cable uses and constructions.

TC-ER rated cables comply with crush and impact requirements of MC cable.