

COPPER 15KV PRIMARY URD CABLE TR-XLP INSULATION - 133% INSULATION LEVEL CONCENTRIC NEUTRAL (1/3 AND FULL) , LLDPE JACKET

CONSTRUCTION:

CONDUCTOR COMPRESSED SOFT DRAWN STRANDED BARE COPPER.

CONDUCTOR SHIELD NONMETALLIC SEMI-CONDUCTING EXTRUDED LAYER.

INSULATION TREE RETARDANT CROSSLINKED POLYETHYLENE (TR-XLP).

INSULATION SHIELD SEMI-CONDUCTING EXTRUSION DIRECTLY OVER INSULATION.

NEUTRAL SOLID BARE ANNEALED UNCOATED COPPER WIRES HELICALLY APPLIED AND UNIFORMLY SPACED.

OVERALL JACKET BLACK LINEAR LOW DENSITY POLYETHYLENE (LLDPE). OUTER JACKET TO HAVE 3 STRIPES FOR IDENTIFICATION.

Charlotte Wire Part#	Size AWG	No. of Strands	Insulation Thickness (in.)	Insulation Diameter (in.)	Neutral Type	Neutral Wire No. x awg	Overall Diameter (in.)	Approx. Net Wt. (Lbs/Mft)
CW07501FN	2	7	.220"	.79"	Full	16 x 14's	1.10"	765
CW07502FN	1	19	.220"	.83"	Full	20 x 14's	1.18"	890
CW07503RN	1/0	19	.220"	.86"	1/3	9 x 14's	1.21"	850
CW07503FN	1/0	19	.220"	.86"	Full	25 x 14's	1.21"	1070
CW07504RN	2/0	19	.220"	.92"	1/3	11 x 14's	1.26"	990
CW07504FN	2/0	19	.220"	.92"	Full	32 x 14's	1.26"	1250
CW07505RN	3/0	19	.220"	.97"	1/3	14 x 14's	1.31"	1140
CW07505FN	3/0	19	.220"	.97"	Full	25 x 12's	1.31"	1480
CW07506RN	4/0	19	.220"	1.01"	1/3	18 x 14's	1.40"	1410
CW07506FN	4/0	19	.220"	1.01"	Full	20 x 10's	1.40"	1820
CW07507RN	250MCM	37	.220"	1.08"	1/3	21 x 14's	1.48"	1630
CW07508RN	350MCM	37	.220"	1.17"	1/3	18 x 12's	1.62"	2150
CW07509RN	500MCM	37	.220"	1.31"	1/3	26 x 12's	1.80"	2920
CW07510RN	750MCM	61	.220"	1.49"	1/3	25 x 10's	1.99"	4100
CW07511RN	1000MCM	61	.220"	1.64"	1/3	32 x 10's	2.17"	5290

APPLICATION:

Suitable as an underground primary residential and commercial distribution cable. May be used in wet or dry locations, installed in underground ducts, or direct burial.

STANDARDS:

AEIC CS-8 for XLP insulation.

ICEA S-94-649 for Insulated Concentric Neutral Cables.